FIELD REPORT

DELLA PENNA ENGINEERING, INC.
21 Whitetail Lane
Parkesburg, PA 19365
TEL: 610-857-0045 FAX: 610-857-0046

DATE 8/4/2010	REPORT NO. 1180
PROJECT Manchester Farms	
LOCATION East Fallowfiled Township	
CONTRACTOR Wagontown Constr.	OWNER Dewey Homes
WEATHER	TEMP °at AM °at PM
PRESENT AT SITE	

To East Fallowfield Township

RECEIVED AUG 09 2010

THE FOLLOWING WAS NOTED:

Requested to check seepage bed on Lot 22. Contractor was not present. Pit was excavated and fabric was in place. Pit measured approximately 43.5' x 15' x 4' deep at shallowest end. Bed area dimensions were modified from the approved permit plan to better fit site conditions however the required 650 sf minimum area was still maintained. Roof leaders were connected and piped to bed. Stone to be place tomorrow morning.

8/6 - Check sidewalk on lot 22 prior to pour. Forms in place and wire fabric and expansion joint also on site. Forms were set to proper depth and widths. Stone bedding also in place. OK to pour.

COPIES TO

Dewey Homes

SIGNED