FIELD REPORT

DELLA PENNA ENGINEERING, INC.
21 Whitetail Lane
Parkesburg, PA 19365
TEL: 610-857-0045 FAX: 610-857-0046

DATE 8/1/2012	REPORT NO. 1226
PROJECT Manchester Farms	
LOCATION Lot 24	
CONTRACTOR Berg	OWNER Dewey Homes
WEATHER Cloudy - hot	TEMP °at AM / °at PM
PRESENT AT SITE No one	

To East Fallowfield Township

RECEIVED SEP 26 2012 By

THE FOLLOWING WAS NOTED:

Request from contractor for inspection of seepage bed prior to stone placement. Bed was dug but no fabric yet. Bed measured roughly 30.5' long x 21.5' wide and depth was 4' at lowest end. Yard drain to be installed and all roof downspouts to be piped to bed.

Contractor stated that he would be placing fabric on sides and top and begin placementof stone tomorrow AM.

COPIES TO

Contractor (via email: Jason@bergconst.com)

SIGNED

DELLA PENNA ENGINEERING, INC.
21 Whitetail Lane
Parkesburg, PA 19365
TEL # 610-857-0045 FAX # 610-857-0046

RECEIVED SEP 26 2012 By