

# FIELD REPORT

**DELLA PENNA ENGINEERING, INC.**  
21 Whitetail Lane  
Parkesburg, PA 19365  
TEL: 610-857-0045 FAX: 610-857-0046

To East Fallowfield Township  
\_\_\_\_\_  
\_\_\_\_\_

DATE	6/15/2010	REPORT NO.	1173
PROJECT	Tull - 80 Rokeby Road		
LOCATION	East Fallowfield Twp.		
CONTRACTOR	Page Excavating	OWNER	Richard Tull
WEATHER		TEMP	°at AM °at PM
PRESENT AT SITE	David Page		


THE FOLLOWING WAS NOTED:

Contractor was installing infiltration bed under basin as approved by CCCD last week. Approximately one-half of the bed had been excavated and stone was being dumped and spread. Fabric was in-place around sides as per plan. Bed width was measured to be 71' (plan calls for 70' ).

Silt fence was installed uphill and downhill of proposed work area and contractor was to keep all sediment away from bed until disturbed areas are stabilized. All other areas of disturbance were almost completely stabilized.

COPIES TO

Page Excavating (fax: 610-869-6216)  
\_\_\_\_\_

SIGNED 

DELLA PENNA ENGINEERING, INC.  
21 Whitetail Lane  
Parkesburg, PA 19365  
TEL # 610-857-0045 FAX # 610-857-0046

RECEIVED  
JUN 18 2010  
BY: Denise Miller