## Denise Miller

**From:** Jill Bukata
**Sent:** Wednesday, July 20, 2011 11:26 AM
**To:** Barry Gathercole; Denise Miller
**Subject:** FW: Ridgecrest Developement

---

**From:** fm47@comcast.net [mailto:fm47@comcast.net]
**Sent:** Wednesday, July 20, 2011 11:09 AM
**To:** Jill Bukata
**Cc:** Anthony Sirna
**Subject:** Ridgecrest Developement

Jill
Tony and I have reviewed the plans for the Ridgecrest development and found no issues with; emergency vehicle access, sizes of the cul-de-sacs, or location of the fire hydrant.

We would suggest that the township road master review the fire hydrant locations as related to snow plowing and clearing operations in the development.

Our assumption also is that the cul-de-sacs will remain open as currently show (with no islands) and that on street parking will not be allowed in the development.

If you have any quesitons, or there are any changes, please let us know.

Thanks
Jim