FIELD REPORT

DELLA PENNA ENGINEERING, INC.
21 Whitetail Lane
Parkesburg, PA 19365
TEL: 610-857-0045 FAX: 610-857-0046

DATE 4/30/2012	REPORT NO. 1222
PROJECT Fieldstone Village	
LOCATION S. Caln & Oaklyn Roads	
CONTRACTOR	OWNER DeLuca
WEATHER Sunny - warm	TEMP °at AM °at PM
PRESENT AT SITE	

To East Fallowfield Township

RECEIVED MAY 02 2012 By DM

THE FOLLOWING WAS NOTED:

Check site per Towsnhip request regarding complaint about soil stockpiles and open inlets. As noted in previous reports as well as CCCD reports, silt fence should be re-installed around soil stockpiles to prevent sediment from leaving site.

Two inlets were found to have plywood over top and one inlet had the grate dropped into the box. These inlets should have proper grates installed as soon as possible. These inlets were all located in the uncompleted section and not in the existing roadways.

COPIES TO

Rouse Chamberlin Homes (receiver)

SIGNED