FIELD REPORT

DELLA PENNA ENGINEERING, INC.
21 Whitetail Lane
Parkesburg, PA 19365
TEL: 610-857-0045 FAX: 610-857-0046

DATE 5/18/2011	REPORT NO. 1197
PROJECT Stone Creek	
LOCATION 310 Misty Patch Road	
CONTRACTOR	OWNER William Oakes
WEATHER Overcast - drizzle	TEMP °at AM / °at PM
PRESENT AT SITE	

To East Fallowfield Township

THE FOLLOWING WAS NOTED:

Follow up site visit in response to complaint about water from Basin C in Stone Creek. Basin had water in it at time of visit however level was below level of outlet hole so no water was being discharged from pipe. Periods of rain had just ended. Heavy rains had occurred over past few days. Ponded water was observed along sides of owner's driveway and other low lying wet areas were noted in floodplain & between driveway and basin in close proximity to the stream.

As noted in previous visit, a berm was installed during the construction of the basin to direct water away from the Oakes property and channel it to the stream. Although the property lines are not visible, the berm/swale appears to have been installed within the Stone Creek open space. There was evidence of water being conveyed from the basin to the stream within the swale. No evidence was observed of the basin discharge leaving the swale / berm or entering the subject property. As noted previously, the standing water on the subject property could be from rain water that had fallen and collected or from seepage from the ground however the source is not evident.

COPIES TO

SIGNED

DELLA PENNA ENGINEERING, INC.
21 Whitetail Lane
Parkesburg, PA 19365
TEL # 610-857-0045 FAX # 610-857-0046

RECEIVED
MAY 24 2011
BY: